

## SPECIAL NOTICE For the Elderly, Infants, Cancer Patients, People with HIV/AIDS or Other Immune Problems

You may be more vulnerable than the general population to certain microbial contaminants such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immuno-compromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline: **1-800-426-4791**.

## QUESTIONS?

If you would like to talk to a District representative about your Water Quality Report, please call **281-861-7265**. For more information from the U.S. Environmental Protection Agency, you may call the EPA's Safe Drinking Water Hotline at **1-800-426-4791**.

**En español:** Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono **281-861-7265**.

## PUBLIC PARTICIPATION OPPORTUNITIES

The Board of Directors of Harris County MUD No. 167 meet at 6:00 PM on the third Wednesday of each month at Phoenix Tower, 3200 Southwest Freeway, Suite 2600, Houston, Texas. You may mail comments to:

**Harris County MUD No. 167**  
**Attn.: Board of Directors**  
**5870 Highway 6 North, Suite 215**  
**Houston, TX 77084**

Or call **281-861-7265**

## ABOUT OUR DRINKING WATER

The Texas Commission on Environmental Quality (TCEQ) has assessed our system and determined that our water meets or exceeds all federal requirements. If your water meets federal standards there may not be any health benefits to purchasing bottled water or point-of-use devices.

## WHERE DO WE GET OUR WATER?

Our drinking water is obtained from groundwater sources. Our water comes from the Chicot aquifer. Texas Commission on Environmental Quality completed an assessment of your source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. If we receive or purchase water from another system, their susceptibility is not included in this report. For more information on source water assessments and protection efforts visit Texas Drinking Water Watch at <http://dww2.tceq.texas.gov/DWW/> or contact H<sub>2</sub>O Consulting at **281-861-7265**.

## WATER LOSS

Harris County MUD No. 167 has completed an audit of their water system required by the Texas Water Development Board. The District's water loss, which includes leaks, water used for maintenance of the system, and inherent meter losses was 37,335,000 gallons, or approximately 8% of the District's usage.

## WATER SOURCES

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

### Contaminants that may be present in source water before treatment include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, and farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Federal Food and Drug Administration Agency regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### HARRIS COUNTY MUNICIPAL UTILITY DISTRICT NO. 167

5870 Highway 6 North, Suite 215 • Houston, TX 77084

281-861-7265



# 2018 DRINKING WATER QUALITY REPORT



**HARRIS COUNTY  
MUNICIPAL UTILITY DISTRICT  
NO. 167**

**PWD ID#: 1012842**

## ALL DRINKING WATER MAY CONTAIN CONTAMINANTS

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline **1-800-426-4791**.

## SECONDARY CONSTITUENTS

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not necessarily causes for health concern. Therefore, secondaries are not required to be reported in this document, but they may greatly affect the appearance and taste of your water. For more information on secondary constituents contact H<sub>2</sub>O Consulting at **281-861-7265**.

## ADDITIONAL HEALTH INFORMATION FOR LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## ABOUT THE TABLES

The attached table contains all of the chemical contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants. All contaminants detected in your water are below state and federal allowed levels. The State of Texas allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently.

HARRIS COUNTY MUD 167 – Lead and Copper (Regulated at the Customer's Tap)								
Year	Contaminant	AL	MCLG	90th Percentile	No. Sites Over AL	Unit of Measure	Violation	Source of Contaminant
2018	Copper	1.3	1.3	0.159	0	ppm	No	Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems
HARRIS COUNTY MUD 167 – Inorganic Contaminants								
Year	Contaminant	Average Level	Range of Detected Levels	MCL	MCLG	Unit of Measure	Violation	Source of Contaminant
2017	Arsenic <sup>1</sup>	6.9	69–6.9	10	0	ppb	No	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
2017	Barium	0.114	0.114–0.114	2	2	ppm	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
2018	Fluoride	0.44	0.44–0.44	4	4	ppm	No	Erosion of natural deposits
2018	Nitrate (measured as Nitrogen)	0.06	0–0.06	10	10	ppm	No	Erosion of natural deposits; runoff from fertilizer use; leaching from septic tanks, sewage
HARRIS COUNTY MUD 167 – Disinfection Byproducts								
Year	Contaminant	Average Level	Range of Detected Levels	MCL	MCLG	Unit of Measure	Violation	Source of Contaminant
2018	Total Trihalomethanes (TTHM) <sup>2</sup>	8	2.1–8.2	80	No Goal	ppb	No	Byproduct of drinking water disinfection
HARRIS COUNTY MUD 167 – Radioactive Contaminants								
Year	Contaminant	Average Level	Range of Detected Levels	MCL	MCLG	Unit of Measure	Violation	Source of Contaminant
2017	Gross Alpha (excluding Radon and Uranium)	3.7	3.7–3.7	15	0	pCi/L	No	Erosion of natural deposits
HARRIS COUNTY MUD 167 – Disinfectant Residual								
Year	Disinfectant	Average Level	Range of Detected Levels	MCL	MCLG	Unit of Measure	Violation	Source of Contaminant
2018	Free Chlorine	1.92	0.87–3.88	4	4	ppm	No	Water additive used to control microbes

## VIOLATIONS

### LEAD AND COPPER RULE

The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.

**Violation Type:** Lead Consumer Notice (LCR)

**Violation Begin:** 04/01/2018

**Violation End:** 05/15/2018

**Violation Explanation:** We failed to provide the results of lead tap water monitoring to the consumers at the location water was tested. These were supposed to be provided no later than 30 days after learning the results.

### PUBLIC NOTIFICATION RULE

The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).

**Violation Type:** Public Notice Rule linked to violation

**Violation Begin:** 08/16/2018

**Violation End:** 2018

**Violation Explanation:** We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.

## DEFINITIONS AND UNIT DESCRIPTIONS

<b>AL</b>	Action Level – The concentration level of a contaminant which, if exceeded, requires a water system to treat water or follow other requirements.
<b>ALG</b>	Action Level Goal – The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
<b>Avg</b>	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
<b>Level 1 Assessment</b>	A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
<b>Level 2 Assessment</b>	A very detailed study of the water system to identify potential problems and determine (if possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
<b>MCL</b>	Maximum Contaminant Level – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
<b>MCLG</b>	Maximum Contaminant Level Goal – The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.
<b>MFL</b>	Million Fibers per Liter (a measure of asbestos)
<b>MRDL</b>	Maximum Residual Disinfection Level – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
<b>MRDLG</b>	Maximum Residual Disinfection Level Goal – The level of a drinking water disinfectant below which there is no known or expected health risk. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
<b>mrem/yr</b>	Millirems per Year (a measure of radiation absorbed by the body)
<b>NA</b>	Not applicable
<b>NTU</b>	Nephelometric turbidity units (a measure of turbidity)
<b>pCi/L</b>	Picocuries per liter (a measure of radioactivity)
<b>ppb</b>	Parts per billion, or micrograms per liter (µg/L), or one ounce in 7,350,000 gallons of water.
<b>ppm</b>	Parts per million, or milligrams per liter (mg/L), or one ounce in 7,350 gallons of water.
<b>ppq</b>	Parts per quadrillion, or picograms per liter (pg/L)
<b>ppt</b>	Parts per trillion, or nanograms per liter (ng/L)
<b>TT</b>	Treatment Technique – a required process intended to reduce the level of a contaminant in drinking water

<sup>1</sup> While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

<sup>2</sup> The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year.

<sup>3</sup> Volatile Organic Compounds are disinfection byproducts. There is no maximum contaminant level for these chemicals at the point of entry to distribution.